



Datos de placas de Celda Seccionadora de media tensión en existencia.

 ORMAZABAL		Anlagentechnik GmbH Werk Krefeld			
Ser. No. 0723S086		Type GAE630 -1LSF630-/5/		MM/YYYY 06/2007	
J_r	24 kV	f_r	50 Hz	P_{re}	0,05 Mpa
J_D	125 kV	U_d	50 kV	m TC	1,57 kg SF ₆ -25 °C
		IAC	AFL	16 kA	
Sammelschiene / Bus bar		I_r	630 A		
		I_k	16 kA	t_k	1 s
		Leistungsschalter Circuit-breaker			
		E_r / M_r	E2 / M1		
		I_r	630 A		
		I_{sc}	16 kA		
		t_k	1 s		
		I_{ma}	40 kA		
		O - 3min. - CO - 3min. - CO DC comp. <20%			
		Erdungsschalter / Earthing switch			
		E_r	E2		
		I_k / I_{ma}	16 / 40 kA		
		t_k	1 s		
Sealed pressure system IEC 60694/02 IEC 62271-100/01, -102/01, -200/03 Betriebsanleitung 12249461 / Operating instruction 12249462					